



<b>TEST REPORT ENVIRONMENTAL EN 60529:1991+A1:2000</b>	
<b>Report Reference No.</b> .....	104703-2TRFENV
<b>Tested by</b> .....	Fabio Mauri 
<b>Verified by</b> .....	Cristian Simone 
<b>Date of issue</b> .....	2008-04-28
<b>Testing Laboratory</b> .....	<b>Nemko Spa</b>
<b>Address</b> .....	Via del Carroccio 4, I-20046 Biassono MI (Italy)
<b>Testing location/ procedure</b> .....	Full application of Harmonised standards <input checked="" type="checkbox"/> Partial application of Harmonised standards <input type="checkbox"/> Other standard testing methods <input type="checkbox"/> Non-standard testing methods <input type="checkbox"/> SINAL accredited test report <input type="checkbox"/>
<b>Testing location/ address</b> .....	Nemko Spa via del Carroccio 4, I-20046 Biassono MI (Italy)
<b>Applicant's name</b> .....	<b>Techno srl</b>
<b>Address</b> .....	via Bancora e Rimoldi , 27- 22070 Guanzate (CO) Italy
<b>Test specification</b>	
<b>Standard</b> .....	EN 60529:1991+A1:2000
<b>Test procedure</b> .....	Nemko WM L0177
<b>Non-standard test method</b> .....	N/A
<b>Test Report Form No.</b> .....	TRF EN60529
<b>TRF Originator</b> .....	Nemko Spa
<b>Master TRF</b> .....	2005-04
<b>Nemko Spa, I-20046 Biassono MI, Italy. All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the Nemko Spa is acknowledged as copyright owner and source of the material. Nemko Spa takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
<b>Test item description</b> .....	Connector box system
<b>Trade Mark</b> .....	Techno
<b>Manufacturer</b> .....	Techno S.r.l.
<b>Model</b> .....	TH 211
<b>Ratings</b> .....	

*This test report may not be partially reproduced, except with the prior written permission of **Nemko Spa***

<b>Test Report No. : 104703-2TRFENV</b>	2008-04-28
	Date of issue

**Type / Model** : TH211

**Equipment** : Connector box system

**Applicant** : Techno srl

**Address** : via Bancora e Rimoldi , 27- 22070 Guanzate (CO) Italy

**Manufacturer** : Techno srl

**Address** : via Bancora e Rimoldi , 27- 22070 Guanzate (CO) Italy

<b>Test Result</b> (according to the standards on page 4)	<b>POSITIVE</b>
--	-----------------

The test report merely corresponds to the test sample.  
It is not permitted to copy extracts of these test result without the written permission of the test laboratory.

# Contents

<b>1</b>	<b><u>TEST STANDARDS</u></b>	<b>4</b>
<b>2</b>	<b><u>SUMMARY</u></b>	<b>4</b>
2.1	POWER SUPPLY SYSTEM UTILISED	5
2.2	SHORT DESCRIPTION OF THE EQUIPMENT UNDER TEST (EUT)	5
2.3	EUT OPERATION MODE:	5
2.4	EUT CONFIGURATION:	5
2.5	PERFORMANCE LEVEL	5
<b>3</b>	<b><u>TEST ENVIRONMENT</u></b>	<b>6</b>
3.1	ADDRESS OF THE TEST LABORATORY	6
3.2	ENVIRONMENTAL CONDITIONS	6
3.3	DEFINITIONS OF SYMBOLS USED IN THIS TEST REPORT	6
3.4	STATEMENT OF THE MEASUREMENT UNCERTAINTY	6
<b>4</b>	<b><u>TEST CONDITIONS AND RESULTS</u></b>	<b>7</b>
4.1	IP 6X	7
4.2	IP X5	8
<b>5</b>	<b><u>USED TEST EQUIPMENT</u></b>	<b>9</b>
<b>6</b>	<b><u>FINALS RESULTS:</u></b>	<b>9</b>
<b>5</b>	<b><u>PHOTOS</u></b>	<b>10</b>

## 1 TEST STANDARDS

The tests were performed according to following standards:

EN 60529:1991+A1:00 Degrees of protection provided by enclosures (IP code)

Nemko WM L0177 Nemko S.p.A. Technical Procedure  
Use of measuring equipment to perform standards tests

Nemko WM L1002 Measurement Uncertainty - Policy and Statement

## 2 SUMMARY

### GENERAL REMARKS:

The dust test was performed in a dust chamber in accordance with clauses 13.4, 13.5.2 of standard EN 60529. The water test was been performed in accordance with clauses 14.2.5 and 14.3 of EN 60529 standard (IPX5).

### FINAL ASSESSMENT:

The protection requirements pertaining to the technical standards and tested operation modes are

- o - fulfilled.
- - not fulfilled.

The equipment under test

- o - fulfils the protection requirements cited on page 4.
- - does not fulfil the protection requirements cited on page 4.

Date of receipt of test sample : 2008-04-03

Testing commenced on : 2008-04-18

Testing concluded on : 2008-04-28

## 2.1 Power supply system utilised

Power supply voltage :  230V/50 Hz / 1 $\phi$   115V/60Hz / 1 $\phi$   
 400V/50 Hz 3PE  400V/50 Hz 3NPE  
 12 V DC  Not relevant for IP test

## 2.2 Short description of the Equipment under Test (EuT)

The E.U.T. is a Connector box system.

Number of tested samples: 1

Serial number:

## 2.3 EuT operation mode:

- unscreened power cables
- customer specific cables

## 2.4 EuT configuration:

EUT was equipped with its specific cable during the tests.

Ø 16mm; Ø 16mm.

## 2.5 Performance level

The EUT complies with all the tests described on paragraph 4 point: if

- the test probe didn't penetrate inside the enclosure;
- the dust is not present inside the enclosure and on live parts after the IP6X test
- no water is present inside the enclosure and on live parts after the IPX5 test.

### 3 TEST ENVIRONMENT

#### 3.1 Address of the test laboratory

Nemko Spa  
 Via Del Carroccio 4  
 I – 20046 Biassono MI – ITALY

#### 3.2 Environmental conditions

During the measurement the environmental conditions were within the listed ranges:

Temperature: 17-28°C

Humidity: 30 ÷ 60%

Atmospheric pressure: 860-1060 hPa

#### 3.3 Definitions of symbols used in this test report

- - The black square indicates that the listed condition, standard or equipment is applicable for this report.
- - The empty circle indicates that the listed condition, standard or equipment is **not** applicable for this report.

#### 3.4 Statement of the measurement uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report according to Nemko SpA Technical Procedure VML1002 and is documented in the quality system acc. to DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

Hereafter the best measurement capability for Nemko Spa laboratory is reported:

<b>6.2 IP Grade Protection</b>					
<b>6.2.1 Water Flow</b>	The measurement uncertainty is the same defined by calibration certificates, giving the table.				
	<table border="1"> <thead> <tr> <th>Range</th> <th>Measurement Uncertainty</th> </tr> </thead> <tbody> <tr> <td>Water flow defined in EN 60529</td> <td>± 2 %</td> </tr> </tbody> </table>	Range	Measurement Uncertainty	Water flow defined in EN 60529	± 2 %
Range	Measurement Uncertainty				
Water flow defined in EN 60529	± 2 %				
<b>6.2.2 Probe Dimension</b>	The measurement uncertainty is the same defined by calibration certificates, giving the table.				
	<table border="1"> <thead> <tr> <th>Range</th> <th>Measurement Uncertainty</th> </tr> </thead> <tbody> <tr> <td>Probe dimensions defined in EN 60529</td> <td>± 2 · 10<sup>-2</sup> · L<sub>m</sub>/m</td> </tr> </tbody> </table>	Range	Measurement Uncertainty	Probe dimensions defined in EN 60529	± 2 · 10 <sup>-2</sup> · L <sub>m</sub> /m
Range	Measurement Uncertainty				
Probe dimensions defined in EN 60529	± 2 · 10 <sup>-2</sup> · L <sub>m</sub> /m				

This table has been extracted from the relevant Technical Procedure VML1002

## 4 TEST CONDITIONS AND RESULTS

### 4.1 IP 6X

Test probe diameter.....: 1 mm  
Enclosure category .....: 1  
Volume hour.....: < 40 volume for hours  
Maximum depression.....: 20mbar  
Test Duration .....: 8h

#### 4.1.2 Description of the test location

Test location: Nemko S.p.a. laboratory

#### 4.1.3 Photo documentation of the test set-up



Typical setup for IP Dust test

#### 4.1.4 Test result

The requirements are: **Fulfilled**

Test probe didn't penetrate inside the enclosure.  
Dust was not present inside the enclosure and on live parts after test.

## 4.2 IP X5

For the test equipment refer to par. 6

Diameter of nozzle ..... : 6.3mm  
Delivery rate..... : 12.5 l/min  
Test duration ..... : 3min.  
Distance to nozzle to E.U.T.....: from 2,5m to 3m

### 4.2.1 Description of the test location

Test location: Water IP room

### 5.2.2 Photo documentation the test set-up



Snooze for IP X5

### 4.1.4 Test result

The requirements are: **Fulfilled**

Water was not present inside the enclosure and on live parts after test. (see photos)



## **5 USED TEST EQUIPMENT**

Equipment used for testing are recorded and saved into the company archive as instruments 104703-INS.doc

It will be made available if requested.

## **6 Finals Results:**

According the EN60529 and A1 the connector models TH211 is considered IP65.

## 5 PHOTOS



E.u.t. general view, same equipment with different section of cable  
**Comply with IP65**

**Internal view, after Test**

